



Ground Floor, No.8/1, 4th Cross,
3rd Main Road, Near Deepanjali Nagar
Metro Station, Deepanjali Nagar,
Bangalore - 560026.

GSTIN/UIN: 29BKFP2021G1ZA

FIRE EXTINGUISHER REFILLING CERTIFICATE

Original

Client Name :

Date : 19-01-2025

Add : Hill Rock National Public School,
101, Brahmadevaragutte, 6th Block,
Vishveshwaraiah Layout, Bangalore - 560091.

This is to certify that the under noted fire extinguisher have been Refilling Certificate
(SLV CER 2025/2026-102)

SR.NO.	DESCRIPTION	NO.	Refilling F/E Date	Next F/E Due Date	Type F/E
01	Recharging of ABC 1kgs Cap Fire Extingusiher	03	19/01/2025	18/01/2026	ABC
02	Recharging of ABC 2kgs Cap Fire Extingusiher	05	19/01/2025	18/01/2026	ABC
03	Recharging of ABC 4kgs Cap Fire Extingusiher	26	19/01/2025	18/01/2026	ABC
04	Recharging of ABC 6kgs Cap Fire Extingusiher	36	19/01/2025	18/01/2026	ABC
05	Recharging of Co2 4.5kgs Cap Fire Extingusiher	02	19/01/2025	18/01/2026	Co2
	TOTAL	72			

The above said extinguisher has been Refilling to the above refer client vide our Dated : 18/01/2025.
We also certify that the above extinguisher are hydraulically tested 100% at 35 bar found satisfactory
& that one no. Of fire extinguisher was randomly tested for performance & found satisfactory as
per IS.

For Hill Rock National Public School
B. I. S. S. S.
Manager

FOR SLV SOLUTIONS

Veda M.N.
Principal
HILL ROCK NATIONAL PUBLIC SCHOOL
(Shree Siddhi Sai Educational Trust)
101, Brahmadevara Gutte, Kodigehalli
Near 6th Block, Vishveshwaraiah Layout
Magadi Road, Bangalore-560 091