



A TO Z ENVIRO TEST HOUSE LLP

Recognised by MoEF & CC, Certified By : ISO 9001 : 2015, ISO 45001 : 2018 & ISO 14001 : 2015
C-56, KSSIDC Industrial Estate, Veerasandra, Hosur Road, Bangalore-560 100.
Ph.: 080-2960 0330 Mob.: 98456 65241 E-mail : enquiry2022.eth@gmail.com

TEST REPORT

Name & Address of the Customer

M/s. HILL ROCK NATIONAL PUBLIC SCHOOL.
SY No.101, Nagarabhavi Off, Magadi Road Bangalore-
560091

Sample Code	ETH/ FEB-25/ 17 2	Report No	ETH/ FEB-25/ 17-2
Date of Sample Collection	04/02/2025	Date of Sample Receipt	04/02/2025
Analysis Commenced Date	05/02/2025	Analysis Completed Date	08/02/2025
Sample Description	RO Water (Pantry)	Report Issue Date	08/02/2025
Qty. Received	2 Ltrs	Sample Received Condition	Good
Sample Appearance	Clear Liquid		
Sampling Details	ETH/QR/F&F/001.		

SL. NO	PARAMETERS	UNIT	RESULTS	Requirement Acceptable Limits	Permissible limit in the absence of alternate source	TEST METHOD
				As per IS 10500: 2012		
Physico Chemical Parameters						
1	Colour	Hazen units	<1.0	5	15	IS 3025(Part -04)2021
2	Odor	--	Agreeable	Agreeable	Agreeable	IS 3025(Part -05)2018
3	pH Value @25°C	--	6.54	6.5-8.5	No relaxation	IS 3025(Part -11) 2022
4	Taste	--	Agreeable	Agreeable	Agreeable	IS 3025(Part -08) 2023
5	Turbidity	NTU	<1.0	1	5	IS 3025(Part -10) 2023
6	Total Dissolved Solids	mg/L	26	500	2000	IS 3025(Part -16) 2023
General Parameters						
7	Calcium as Ca	mg/L	3.9	75	200	IS 3025(Part -40)1991(RA2019)
8	Chloride as Cl	mg/L	6.7	250	1000	IS 3025(Part -32)1988(RA2019)
9	Magnesium as Mg	mg/L	2.9	30	100	IS 3025(Part -46) 2023
10	Total Hardness as CaCO ₃	mg/L	21.6	200	600	IS 3025(Part -21)2009(RA2019)
11	Total Alkalinity as CaCO ₃	mg/L	14.8	200	600	IS 3025(Part -23) 2023
12	Total Ammonia as NH ₃ -N	mg/L	0.1	0.5	No relaxation	IS 3025(Part -34)1988(RA2019)
13	Fluoride as F	mg/L	<0.1	1.0	1.5	IS 3025(Part -60)2008(RA2019)
14	Nitrate as NO ₃	mg/L	6.2	45	No relaxation	IS 3025(Part -34)1988 (RA2019)
15	Sulphate as SO ₄	mg/L	8.3	200	400	IS 3025(Part 24/Sec I)2022
16	Residual Free Chlorine	mg/L	<0.1	0.2	1.0	IS 3025 (Part -26)2021
17	Sulfide as S ²⁻	mg/L	Nil	0.05	No relaxation	IS 3025(Part -29) 2022



Page 1 of 2

For Hill Rock National Public School

B. V. S. Manager

Reviewed & Authorized Signatory

HILL ROCK NATIONAL PUBLIC SCHOOL
(Shree Siddhi Sai Educational Trust)
101, Brahmadevara Gutte, Kodigehalli
Near 6th Block, Vishweshwaraiah Layout
Magadi Road, Bangalore-560 091

NOTE : 1. The result listed above pertain only to the tested samples and applicable parameters. 2. Samples will be stored for a period of 15 Days unless otherwise specified. 3. This report is not to be reproduced either wholly or in part and can not be used as evidence in the court of law and should not be used in any advertising media without prior written permission. 4. Sampling not done by us unless specified. 5. Total liability of our lab is limited to the Invoice Amount & any disputes arising out of this report are subject to Bangalore Jurisdiction only. 6. Laboratory is not responsible for the authenticity of photocopied test reports. ETH/QR/F&F/069 Issue date 01/03/2024



A TO Z ENVIRO TEST HOUSE LLP

Recognised by MoEF & CC, Certified By : ISO 9001 : 2015, ISO 45001 : 2018 & ISO 14001 : 2015
C-56, KSSIDC Industrial Estate, Veerasandra, Hosur Road, Bangalore-560 100.
Ph.: 080-2960 0330 Mob.: 98456 65241 E-mail : enquiry2022.eth@gmail.com

TEST REPORT

Name & Address of the Customer

M/s. HILL ROCK NATIONAL PUBLIC SCHOOL
SY No.101, Nagarabhavi Off, Magadi Road Bangalore-
560091

Sample Code	ETH/FEB-25/17-2	Report No	ETH/FEB-25/17-2
Date of Sample Collection	04/02/2025	Date of Sample Receipt	04/02/2025
Analysis Commenced Date	05/02/2025	Analysis Completed Date	08/02/2025
Sample Description	RO Water (Pantry)	Report Issue Date	08/02/2025
Qty. Received	250 ml	Sample Received Condition	Good
Sample Appearance	Clear Liquid		
Sampling Details	ETH/QR/F&F/001.		

SL. NO	PARAMETERS	UNIT	RESULTS	Requirement Acceptable Limits	Permissible limit in the absence of alternate source	TEST METHOD
				As per IS 10500: 2012		
1	Arsenic as As	mg/L	<0.01	0.01	0.05	APHA 24 th Edition 3120B
2	Boron as B	mg/L	0.02	0.5	1.0	APHA 24 th Edition 3120B
3	Cadmium as Cd	mg/L	<0.001	0.003	No relaxation	APHA 24 th Edition 3120B
4	Total Chromium as Cr	mg/L	<0.001	0.05	No relaxation	APIIA 24 th Edition 3120B
5	Copper as Cu	mg/L	<0.001	0.05	1.5	APHA 24 th Edition 3120B
6	Iron as Fe	mg/L	0.02	0.3	No relaxation	APHA 24 th Edition 3120B
7	Lead as Pb	mg/L	<0.01	0.01	No relaxation	APHA 24 th Edition 3120B
8	Nickel as Ni	mg/L	<0.003	0.02	No relaxation	APHA 24 th Edition 3120B
9	Zinc as Zn	mg/L	0.02	5	15	APHA 24 th Edition 3120B
10	Aluminum as Al	mg/L	0.01	0.03	0.2	APHA 24 th Edition 3120B
11	Barium as Ba	mg/L	0.01	0.7	No relaxation	APHA 24 th Edition 3120B
12	Manganese as Mn	mg/L	0.01	0.1	0.3	APHA 24 th Edition 3120B

Remarks: The given sample meets the IS 10500:2012 requirements for the above tested Parameter.

Note: Sample tested as received.

*****End of the Report*****

For Hill Rock National Public School

Manager



Veda M.N.
Principal
HILL ROCK NATIONAL PUBLIC SCHOOL
(Shree Siddhi Sai Educational Trust)
101, Brahmadevara Gutte, Kodigehalli
Near 6th Block, Vishweshwaraiah Layout
Magadi Road, Bangalore-560 091

Reviewed & Authorized Signatory

NOTE: 1. The result listed above pertain only to the tested samples and applicable parameters. 2. Samples will be stored for a period of 15 Days unless otherwise specified. 3. This report is not to be reproduced either wholly or in part and can not be used as evidence in the court of law and should not be used in any advertising media without prior written permission. 4. Sampling not done by us unless specified. 5. Total liability of our lab is limited to the Invoice Amount & any disputes arising out of this report are subject to Bangalore Jurisdiction only. 6. Laboratory is not responsible for the authenticity of photocopied test reports. ETH/QR/F&F/069 Issue date 01/03/2024

Enewate Projects Pvt Ltd

No. 41, Mountain Road, 1st block east
Jayanagar, Bengaluru – 560011
Email: sumanth@enewate.com
Contact: 9886674268

15.04.2023

To:

Hill Rock National Public School,
Ullal Uppanagar,
Bengaluru,
Karnataka 560110

Site Name: Hill Rock National Public School
Contractor: Enewate Projects Private Limited

Subject: Completion certificate for the 60 KLD STP at Hill Rock National Public School.

Dear Sir,

With reference to the above subject, the completion certificate for 60 KLD Sewage Treatment Plant at Hill Rock National Public School, Ullal Uppanagar, Bengaluru, Karnataka 560110 is hereby issued, subject to the following conditions:

- The STP comprises of screening and biological treatment of anaerobic followed by aeration, tertiary treatment comprising of pressure sand filtration along with disinfection through chlorination is installed. The treated water will be used for gardening and flushing as per the feasibility report.
- The STP is installed as per drawings submitted refer schedule 1.
- The STP commissioned and plant is working satisfactorily. The test run is done by our technician Mr, Prem Kumar V in presence of your concerned staff.
- Reuse of the treated water shall be as per norms only.

Providing you with the best services as always.

Yours faithfully,

For Enewate Projects Pvt. Ltd



Head Operation